

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Ref. No.

1560

Date:


09/05/2026

It is certified that an inspection team headed by Dinesh kumar (Junior Engineer) (Name of officers with designation) from P.H.D Nawada PHED inspected the **R.P. International School** Address: **Matuk Bigha, Hisua Nawada, Pin-805111.** (Name and address of the school) on - 16.04.2026 (Date of inspection) and on the basis of Water Test Report (Attached) report no 216 Dated: 05.05.2026 of District Level Water Testing Laboratory (PHED Lab) certified that the **R.P. International School, Matuk Bigha, Hisua Nawada** (Name Of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintain the hygienic sanitation condition in the school building & campus as per norms prescribe by the central/state/U.T. Govt.

This certificate is valid till Six months (As per date of issue).

Signature with Seal:

Name:-

for 
Designation:- Executive Engineer
Executive Engineer
Name & Address of the
P. H. Division Nawada
05.05.2026

Office/Department

To,

The

R.P. International School Address: Matuk Bigha, Hisua Nawada, Pin-805111.

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED[] Lab/local bod

Government of Bihar Public Health Engineering Department Water Quality Report

District:- Nawada

Sample Collected by:- MUKESH KUMAR																Date of Sampling :16-04-2026			
Sl. NO.	Block	Panchayat	Village	Name of Nearest Place	Test Report											Source of water	Remarks		
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	ALK	F					
1	2	3	4	6	7	8	9	10	11	12	13	14	15	16	17	18			
1	HISUA	CHHATTIYAR	MATUK BIGHA	R.P. INTERNATIONAL SCHOOL HISUA, NAWADA	7.43	1.24	611	398	202	53	16.32	20	180	1.0	Tap Water				
Desirable Limit* (IS10500:2012)					6.5	1.0	500	500	200	75	30	250	200	1.0					
Permissible Limit* in absence of alternate source					8.5	5.0	2000	2000	600	200	100	1000	600	1.5					

Mukesh Kumar
25.05.2026
Chemist
P.H. Division, Nawada

Mukesh Kumar
05/05/26
Assistant Engineer
P.H.Sub, Division, Nawada

Mukesh Kumar
05/05/26
Executive Engineer
P.H. Division, Nawada